

PERFORMANCE TEST REPORT SUMMARY

SYSTEM TYPE: RS3000 PE Rainscreen ACM Panel System

TESTING PERFORMED BY: Architectural Testing Inc.



TEST METHOD	TITLE OF TEST	RESULTS
ASTM E 283	AIR LEAKAGE 75 PA (1.57 PSF)	0.6 L/s/m ² (0.12 cfm/ft ²)
ASTM E 1233	PRESSURE CYCLING Cycle Time Lag Cycle Pressure Difference	0.11 sec. lead 7 Pa (0.14psf) PASS
ASTM E 331	STATI WATER PENETRATION 720 Pa (15.04 psf)	<0.01 m ² (<0.01 ft ²) PASS
AAMA 501.1	DYNAMIC WATER PENETRATION 720 Pa (15.04 psf)	<0.01 m ² (<0.01 ft ²) PASS

** REFERENCE TEST REPORT C8510.01-109-44 for further information.